

**H519 WINCHESTER HIGH LEVEL WATER SUPPLY ZONE**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
ALUMINIUM	ugAl/l	200	24	<6.9	11.96667	14.5	0
AMMONIUM (AMMONIA AND AMMONIUM IONS)	mgNH4/l	0.5	8	<0.008	0.0095	0.01	0
ANTIMONY	ugSb/l	5	8	0.06	0.0675	0.07	0
ARSENIC	ugAs/l	10	8	0.12	0.15375	0.18	0
BENZO A PYRENE	ug/l	0.01	8	<0.00042	0.00044	0.00057	0
CADMIUM	ugCd/l	5	8	<0.01	0.025	0.03	0
CHROMIUM	ugCr/l	50	8	0.08	0.1575	0.18	0
COLIFORM BACTERIA	Number/100ml	0	36	0	0	0	0
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	24	0	2.91667	67	0
COLOUR	mg/l Pt/Co	20	24	<3	<3	<3	0
COPPER	mgCu/l	2	8	0.0174	0.19519	0.694	0
E.COLI	Number/100ml	0	36	0	0	0	0
ENTEROCOCCI	Number/100ml	0	8	0	0	0	0
FREE CHLORINE	mg/l as Cl2		36	0.12	0.34056	0.52	0
HYDROGEN ION (PH)	pH value	6.5 - 9.5	24	7.26	7.42	7.6	0
IRON	ugFe/l	200	24	<3.72	9.83042	40.3	0
LEAD	ugPb/l	10	8	0.05	0.55375	1.06	0
MANGANESE	ugMn/l	50	24	<0.3	0.67708	1.1	0
NICKEL	ugNi/l	20	8	0.66	1.09875	1.71	0
NITRATE	mgNO3/l	50	8	38.6	41.25	42.4	0
NITRITE	mgNO2/l	0.5	8	<0.002	0.00288	0.005	0
NITRITE/NITRATE FORMULA	Number	1	8	0.77	0.825	0.85	0
ODOUR	Diln. No.	No Abnormal Change	48	0	0	0	0
PAH - SUM OF 4 SUBSTANCES	ug/l	0.1	8	0	0.00063	0.003	0
SELENIUM	ugSe/l	10	8	<0.32	0.38625	0.46	0
SODIUM	mgNa/l	200	8	8.25	8.98125	9.5	0
TASTE	Diln. No.	No Abnormal Change	48	0	0	0	0
TERACHLOROETHENE/TRICHLOROETHENE SUM	ug/l	10	8	0	0	0	0
TETRACHLOROMETHANE	ug/l	3	8	<0.16	<0.16	<0.16	0
TOTAL CHLORINE	mg/l as Cl2		36	0.17	0.39194	0.59	0
TRIHALOMETHANES (SUM OF IDENTIFIED THMS)	ug/l	100	8	6.24	9.66875	16.09	0
TURBIDITY	NTU	4	24	<0.13	0.18375	0.58	0

**EASTON WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
1,2 DICHLOROETHANE	ug/l	3	8	<0.16	<0.16	<0.16	0
ALDRIN	ug/l	0.03	8	<0.008	<0.008	<0.008	0
ATRAZINE	ug/l	0.1	8	<0.004	0.0045	0.006	0
BENTAZONE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
BENZENE	ug/l	1	8	<0.06	<0.06	<0.06	0
BORON	mgB/l	1	8	0.0144	0.02971	0.0319	0
BROMATE	ugBr03/l	10	8	<0.07	0.11625	0.2	0
CARBENDAZIM	ug/l	0.1	8	<0.005	<0.005	<0.005	0
CHLORIDE	mgCl/l	250	8	18.5	20.6625	23.3	0
CLOSTRIDIUM PERFRINGENS	Number/100ml	0	8	0	0	0	0
COLIFORM BACTERIA	Number/100ml	0	365	0	0	0	0
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	366	0	0.16667	3	0
CONDUCTIVITY	uS/cm	2500	52	518	547.67308	583	0
CYANIDE	ugCN/l	50	8	<1.2	<1.2	<1.2	0
DIELDRIN	ug/l	0.03	8	<0.009	<0.009	<0.009	0
E.COLI	Number/100ml	0	365	0	0	0	0
FLUORIDE	mgF/l	1.5	8	0.08	0.085	0.09	0
FLUOROXYPYR	ug/l	0.1	8	<0.008	<0.008	<0.008	0
FREE CHLORINE	mg/l as Cl2		367	0.3	0.58564	0.83	0
GROSS ALPHA	Bq/l	0.1	8	<0.02	0.02863	0.034	0
GROSS BETA	Bq/l	1	8	0.014	0.02125	0.028	0
HEPTACHLOR	ug/l	0.03	8	<0.005	<0.005	<0.005	0
HEPTACHLOR EPOXIDE	ug/l	0.03	8	<0.007	<0.007	<0.007	0
MERCURY	ugHg/l	1	8	<0.04	0.05	0.06	0
METALDEHYDE	ug/l	0.1	8	<0.007	<0.007	<0.007	0
NITRITE	mgNO2/l	0.5	8	<0.002	0.00275	0.003	0
PENDIMETHALIN	ug/l	0.1	8	<0.009	<0.009	<0.009	0
PESTICIDES - TOTAL SUBSTANCES	ug/l	0.5	8	0	0.0005	0.004	0
PIRIMICARB	ug/l	0.1	8	<0.016	<0.016	<0.016	0
PROPAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
PROPICONAZOLE	ug/l	0.1	8	<0.007	0.0075	0.009	0
QUINMERAC	ug/l	0.1	8	<0.006	0.00825	0.009	0
SIMAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
SULPHATE	mgSO4/l	250	8	12.1	13.425	14.7	0
TOTAL CHLORINE	mg/l as Cl2		367	0.3	0.60973	0.93	0
TOTAL ORGANIC CARBON	mgC/l	No Abnormal Change	8	<0.7	0.705	0.72	0
TRIEAZINE	ug/l	0.1	8	<0.004	0.00425	0.005	0
TURBIDITY	NTU	1	367	<0.13	0.15218	0.46	0

**OTTERBOURNE SW WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
1,2 DICHLOROETHANE	ug/l	3	8	<0.16	<0.16	<0.16	0
2,4-D	ug/l	0.1	8	<0.011	<0.011	<0.011	0
ALDRIN	ug/l	0.03	8	<0.008	<0.008	<0.008	0
BENTAZONE	ug/l	0.1	8	<0.005	0.00575	0.007	0
BENZENE	ug/l	1	8	<0.06	<0.06	<0.06	0
BORON	mgB/l	1	8	0.02	0.03041	0.0319	0
BOSCALID	ug/l	0.1	8	<0.008	<0.008	<0.008	0
BROMATE	ugBr03/l	10	8	0.13	0.19125	0.3	0
CARBENDAZIM	ug/l	0.1	8	<0.005	<0.005	<0.005	0
CARBETAMIDE	ug/l	0.1	8	<0.009	0.0125	0.013	0
CHLORIDE	mgCl/l	250	8	26.3	30.9	34	0
CHLORMEQUAT	ug/l	0.1	8	<0.003	0.00488	0.008	0
CHLOROTHALONIL	ug/l	0.1	8	<0.006	<0.006	<0.006	0
CHLORTOLURON	ug/l	0.1	8	<0.005	0.00675	0.007	0
CLOPYRALID	ug/l	0.1	8	<0.011	<0.011	<0.011	0
CLOSTRIDIUM PERFRINGENS	Number/100ml	0	8	0	0	0	0
COLIFORM BACTERIA	Number/100ml	0	362	0	0	0	0
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	363	0	0.16804	5	0
CONDUCTIVITY	uS/cm	2500	104	502	564.53846	606	0
CYANIDE	ugCN/l	50	8	<1.2	1.225	1.4	0
CYPROCONAZOLE	ug/l	0.1	8	<0.006	0.00688	0.007	0
DICAMBA	ug/l	0.1	8	<0.012	<0.012	<0.012	0
DICHLORPROP	ug/l	0.1	8	<0.01	<0.01	<0.01	0
DIELDRIN	ug/l	0.03	8	<0.009	<0.009	<0.009	0
DIFLUFENICAN	ug/l	0.1	8	<0.009	<0.009	<0.009	0
E.COLI	Number/100ml	0	362	0	0	0	0
EPOXICONAZOLE	ug/l	0.1	8	<0.005	0.00513	0.006	0
FENPROPIMORPH	ug/l	0.1	8	<0.01	<0.01	<0.01	0
FLUFENACET	ug/l	0.1	8	<0.008	<0.008	<0.008	0
FLUORIDE	mgF/l	1.5	8	0.08	0.085	0.1	0
FLUOROXYPYR	ug/l	0.1	8	<0.008	<0.008	<0.008	0
FLUTRIAFOL	ug/l	0.1	8	<0.005	<0.005	<0.005	0
FLUXAPYROXAD	ug/l	0.1	8	<0.009	0.00913	0.01	0
FREE CHLORINE	mg/l as Cl2		363	0.45	0.79537	1.01	0
GLYPHOSATE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
HEPTACHLOR	ug/l	0.03	8	<0.005	<0.005	<0.005	0
HEPTACHLOR EPOXIDE	ug/l	0.03	8	<0.007	<0.007	<0.007	0
MCPA	ug/l	0.1	8	<0.006	<0.006	<0.006	0

**OTTERBOURNE SW WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
MECOPROP	ug/l	0.1	8	<0.009	<0.009	<0.009	0
MEPIQUAT CHLORIDE	ug/l	0.1	8	<0.004	0.0055	0.008	0
MERCURY	ugHg/l	1	8	<0.04	0.0475	0.06	0
METALDEHYDE	ug/l	0.1	8	<0.007	<0.007	<0.007	0
METAZACHLOR	ug/l	0.1	8	<0.005	0.00588	0.006	0
NITRITE	mgNO2/l	0.5	8	<0.002	0.00275	0.003	0
PENDIMETHALIN	ug/l	0.1	8	<0.009	<0.009	<0.009	0
PESTICIDES - TOTAL SUBSTANCES	ug/l	0.5	8	0	0.00388	0.007	0
PICLORAM	ug/l	0.1	8	<0.016	<0.016	<0.016	0
PIRIMICARB	ug/l	0.1	8	<0.016	<0.016	<0.016	0
PROPICONAZOLE	ug/l	0.1	8	<0.007	0.00725	0.009	0
PROPYZAMIDE	ug/l	0.1	8	<0.009	<0.009	<0.009	0
PROSULFOCARB	ug/l	0.1	8	<0.006	0.0095	0.01	0
QUINMERAC	ug/l	0.1	8	<0.006	0.00863	0.009	0
SPIROXAMINE	ug/l	0.1	8	<0.005	0.0055	0.009	0
SULPHATE	mgSO4/l	250	8	13.3	13.975	14.9	0
TEBUCONAZOLE	ug/l	0.1	8	<0.005	0.00513	0.006	0
TERBUTHYLAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
TOTAL CHLORINE	mg/l as Cl2		363	0.42	0.85284	1.26	0
TOTAL ORGANIC CARBON	mgC/l	No Abnormal Change	8	<0.7	0.85125	1.03	0
TRIALATE	ug/l	0.1	8	<0.006	<0.006	<0.006	0
TRICLOPYR	ug/l	0.1	8	<0.016	<0.016	<0.016	0
TURBIDITY	NTU	1	363	<0.13	0.17862	0.5	0

**OTTERBOURNE GW WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
1,2 DICHLOROETHANE	ug/l	3	8	<0.16	<0.16	<0.16	0
2,4-D	ug/l	0.1	8	<0.011	<0.011	<0.011	0
ALDRIN	ug/l	0.03	8	<0.008	<0.008	<0.008	0
ATRAZINE	ug/l	0.1	8	<0.004	0.00463	0.006	0
ATRAZINE DESETHYL	ug/l	0.1	8	0.008	0.00913	0.011	0
ATRAZINE DESISOPROPYL	ug/l	0.1	8	<0.008	0.00825	0.009	0
BENTAZONE	ug/l	0.1	8	0.006	0.00888	0.01	0
BENZENE	ug/l	1	8	<0.06	<0.06	<0.06	0
BORON	mgB/l	1	8	<0.0319	<0.0319	<0.0319	0
BOSCALID	ug/l	0.1	8	<0.008	<0.008	<0.008	0
BROMATE	ugBr03/l	10	8	<0.1	0.15	0.2	0
CARBENDAZIM	ug/l	0.1	8	<0.005	<0.005	<0.005	0
CHLORIDE	mgCl/l	250	8	21.5	22.45	23.2	0
CHLORTOLURON	ug/l	0.1	8	<0.005	0.0065	0.007	0
CLOSTRIDIUM PERFRINGENS	Number/100ml	0	8	0	0	0	0
COLIFORM BACTERIA	Number/100ml	0	360	0	0	0	0
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	361	0	0.22438	12	0
CONDUCTIVITY	uS/cm	2500	154	407	559.0974	610	0
CYANAZINE	ug/l	0.1	8	<0.004	0.00475	0.007	0
CYANIDE	ugCN/l	50	8	<1.2	<1.2	<1.2	0
DICAMBA	ug/l	0.1	8	<0.012	<0.012	<0.012	0
DIELDRIN	ug/l	0.03	8	<0.009	<0.009	<0.009	0
E.COLI	Number/100ml	0	360	0	0	0	0
EPOXICONAZOLE	ug/l	0.1	8	<0.005	0.00525	0.006	0
FENPROPIMORPH	ug/l	0.1	8	<0.01	<0.01	<0.01	0
FLUORIDE	mgF/l	1.5	8	0.08	0.09	0.11	0
FLUTRIAFOL	ug/l	0.1	8	<0.005	<0.005	<0.005	0
FREE CHLORINE	mg/l as Cl2		361	0.28	0.74632	0.89	0
GLYPHOSATE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
HEPTACHLOR	ug/l	0.03	8	<0.005	<0.005	<0.005	0
HEPTACHLOR EPOXIDE	ug/l	0.03	8	<0.007	<0.007	<0.007	0
ISOPROTURON	ug/l	0.1	8	<0.005	<0.005	<0.005	0
MCPA	ug/l	0.1	8	<0.006	<0.006	<0.006	0
MCPB	ug/l	0.1	8	<0.008	<0.008	<0.008	0
MECOPROP	ug/l	0.1	8	<0.009	<0.009	<0.009	0
MERCURY	ugHg/l	1	8	<0.04	0.045	0.06	0
METALDEHYDE	ug/l	0.1	8	<0.006	0.00688	0.007	0
METAZACHLOR	ug/l	0.1	8	<0.005	0.00575	0.006	0

**OTTERBOURNE GW WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
METHABENZTHIAZURON	ug/l	0.1	8	<0.005	0.00525	0.006	0
NITRITE	mgNO2/l	0.5	8	<0.002	0.0025	0.003	0
PENDIMETHALIN	ug/l	0.1	8	<0.009	<0.009	<0.009	0
PESTICIDES - TOTAL SUBSTANCES	ug/l	0.5	8	0.015	0.02538	0.031	0
PICLORAM	ug/l	0.1	8	<0.016	<0.016	<0.016	0
PROMETRYN	ug/l	0.1	8	<0.004	0.00425	0.005	0
PROPAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
SIMAZINE	ug/l	0.1	8	<0.005	0.00588	0.007	0
SPIROXAMINE	ug/l	0.1	8	<0.005	0.006	0.009	0
SULPHATE	mgSO4/l	250	8	12.7	13.2125	14.2	0
TOTAL CHLORINE	mg/l as Cl2		361	0.46	0.78285	1.1	0
TOTAL ORGANIC CARBON	mgC/l	No Abnormal Change	8	<0.7	0.73	0.85	0
TRIALATE	ug/l	0.1	8	<0.006	<0.006	<0.006	0
TRIFLURALIN	ug/l	0.1	8	<0.004	0.00425	0.005	0
TRIFLURALIN	ug/l	0.1	8	<0.007	<0.007	<0.007	0
TURBIDITY	NTU	1	361	<0.13	0.15662	0.47	0