

# The Green, Southwick Infiltration Plan

Appendix A – Status of Planned Actions July 2024



from  
**Southern  
Water** 

The Southern Water logo graphic consists of three stylized, wavy blue lines of varying lengths, positioned to the right of the text "Southern Water".


## Summary of work completed

Action	Km of sewer
Length Surveyed by CCTV	2.47
Length Surveyed by Electroscan	0.0
Length with no work required	1.79
Length Sealed	0.68
Length to be sealed	0.52
Manholes sealed	5
Manholes to be sealed	1

Reporting Year	Surveyed (km)	Sewers Sealed (km)	Manholes Sealed
2014	0.93	0	0
2015	1.45	0.3	5
2016	0	0.08	0
2017	0	0	0
2018	0.09	0	0
2019	0	0.21	0
2020	0	0	0
2021	0	0	0
2022	0	0	0
2023	0	0	0
2024	0	0.09	0
<b>Total</b>	<b>2.47</b>	<b>0.68</b>	<b>5</b>

# Reference Plan





## Detailed plan 1

Note – sewers shown as surveyed by cctv or Electroscan (green line) with no corresponding sealing work have been determined to not require rehabilitation. The use of storm harvester data will be used at some point in the future to target inspections and find infiltration

