



NOTES

1. ALL DIMENSIONS ARE MILLIMETERS UNLESS OTHERWISE SPECIFIED.
2. DO NOT SCALE FROM THIS DRAWING. ONLY WRITTEN DIMENSIONS ARE TO BE USED.
3. ALL WORKS TO BE CONSTRUCTED IN ACCORDANCE WITH WRc SEWERS FOR ADOPTION AND THE SPECIFIC REQUIREMENTS OF SOUTHERN WATER.
4. HYDROBRAKE TO BE INSTALLED BEFORE COVER SLAB FINALLY FIXED IN PLACE.
5. ALL CONCRETE TO GIVE CLASS 4 SULPHATE RESISTANCE GEN 3.
6. FIRST RING TO BE PLACED WHILST BASE IS CAST

NOTES FOR DESIGNER

* SUDS

ANY SUDS PIPEWORK THAT IS TO BE ADOPTED BY THE SEWERAGE UNDERTAKER WILL NEED TO BE DESIGNED ON THE BASIS THAT ALL HARD SURFACES CONTRIBUTE RUNOFF AT THE NORMAL RATE EVEN IF IT IS ATTENUATED OR REDUCED IN VOLUME BY THE SUDS COMPONENTS. THIS IS A PRECAUTION WHICH IS CURRENTLY BEING TAKEN TO ENSURE THAT LONG-TERM FAILURE OR CHANGE OF DRAINAGE PRACTICE IN THE FUTURE WILL NOT RESULT IN FLOODING DUE TO PIPE CAPACITIES BEING OVERLOADED, WHICH WILL REQUIRE FUTURE MODIFICATION OF THE NETWORK. EXCEPTIONS TO THIS RULE WILL NEED TO BE AGREED SPECIFICALLY WITH THE ADOPTING AUTHORITY.

REV.	DATE	DESCRIPTION	BY

COMPANY DETAILS:

CONTRACTORS DRAWING NO.	REVISION
-------------------------	----------

PROJECT TITLE
TYPICAL DETAILS
NOT FOR CONSTRUCTION

DRAWING TITLE
CONTROL CHAMBER DETAIL

SCALE N.T.S	DRAWN	DATE	SIZE
DESIGNED	CHECKED	APPROVED	DATE
DISCIPLINE	STATUS	SITE	

DRAWING NO. 7.....	REVISION
-----------------------	----------